

# TEST CERTIFICATE

## Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **coating**

Article description: LOBADUR 2K FactoryStyle /  
LOBACARE SportCare

Kind of material: mineral filler with factory-made coating structure

Material structure: 1. Substrate: mineral filler  
2. Primer: 1 x LOBADUR FactoryBase  
(consumption: 100 g/m<sup>2</sup>)  
3. Sealing: 1 x LOBADUR 2K FactoryStyle  
(consumption: 100 g/m<sup>2</sup>)  
4. Care product: LOBACARE SportCare  
(consumption: 35 g/m<sup>2</sup>)

Dimensions: length and width variable, d = 5,0 mm

Surface: factory lacquered, unprofiled, even, fine-rough, matt-glossy

Producer/supplier: LOBA GmbH & Co. KG  
Leonberger Str. 56-62  
71254 Ditzingen

Client: LOBA GmbH & Co. KG  
Leonberger Str. 56-62  
71254 Ditzingen

Certificate No.: 92532002.001e

Test date: 09.12.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)  
"Testing of floor coverings - Determination of the anti-slip property -  
Workrooms and fields of activities with slip danger - Walking method - Ramp test"  
The delivery of the test material took place in ready-to-test surface condition.

Test result: Average total acceptance angle: **6,3°**

Assessment: **Classification group of anti-slip property: R9**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltkemeyer



Großburgwedel, 22.02.2021  
Schu/ke

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –  
**SÄUREFLIESNER-VEREINIGUNG E.V.**

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de  
Nach DIN EN ISO/IEC 17025 durch die DAkkS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00  
aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

