

TEST CERTIFICATE

Determination of the anti-slip property of floor coverings in workrooms and fields of activities with slip danger

Tested material: **wood/wood composite material**

Kind of material (wood): decking boards, smooth with factory coating structure (spruce/pine)

Dimensions: length variable, width: 14 [cm], thickness 25 mm

Colour: spruce/pine floorboards: light brown

Surface: even, wood grain structure

Addition: coating structure:
1. Substrate: decking board
2. Primer: DeckPrepare
(consumption: 1 x 118 g/m²)
3. Sealing: Deckoil transparent
(consumption: 1 x 110 g/m²)

Hersteller/Lieferer: LOBA GmbH & Co. KG
Leonberger Str. 56-62
71254 Ditzingen

Client: LOBA GmbH & Co. KG
Leonberger Str. 56-62
71254 Ditzingen

Certificate No.: 92542006.001e

Test date: 09.12.2020

Sampling: Sent by the customer to the research institute

Test method: **DIN 51130** (edition 02/2014)
"Testing of floor coverings - Determination of the anti-slip property – Workrooms and fields of activities with slip danger - Walking method - Ramp test"
The delivery of the test material took place in ready-to-test surface condition.
Specified joint width: 3-4 mm
Test direction parallel to wood grain/plank length

Test result: Average total acceptance angle: **12,0°**


Assessment: **Classification group of anti-slip property: R10**

SÄUREFLIESNER-VEREINIGUNG E. V.

Institut für Wand- und Bodenbeläge

Managing Director

Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 13.01.2021
Schu/ed

This test certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test specimen. The certificate is given for 5 years (starting from test date). Publication and reproduction of this certificate is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –
SÄUREFLIESNER-VEREINIGUNG E.V.

Im Langen Felde 4, 30938 Burgwedel · Telefon (0 51 39) 99 82-0 · Telefax (0 51 39) 99 82-40 · E-Mail: info@saeurefliesner.de
Nach DIN EN ISO/IEC 17025 durch die DAKKS akkreditierte Prüfstelle. Die Akkreditierung gilt für die in der Urkunde D-PL-18372-01-00 aufgeführten Bereiche. Vom DIBt nach LBO unter der Kenn-Nr. NDS 20 anerkannte und nach EU-BauPVO notifizierte Stelle NB 1212.

